

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° CM - 19 - P - 076

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from mardi 11 juin 2019

Material presents by : **BESTITCH INDUSTRIA TEXTIL LDA**Zona Industrial de Mide
4815-169 GUIMARAESTrade mark: **FLANNELE 140 / FLANNELE 325**

Summary description

Kind of textile Woven

Composition 100% Coton

Mass per unit area 140 g/m² à 325 g/m²

Kind of Fire retardant Par foulardage

Color Toutes couleurs

Nature of the test : Electrical burner test

Classification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) 12 months starting from the implementation in a regulated building

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Recommendation of Customer

Taking into account the criteria resulting from the tests annexed described in the test report N^oFE 19-0197-0911

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized if the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le jeudi 20 juin 2019

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE



Only the french version remains valide

Institut technologique FCBA : Forêt, Bois - construction, Ameublement